



Certificate of Constancy of performance

0051 – CPR – 1929

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Product description : **Single core cable without sheath**

Designation: **FS17 450/750 V**

Sections: **1 ÷ 6 mm²**

Reaction to fire behaviour : **Cca**
Smoke production : **s3**
Flaming droplets/particles: **d1**
Acidity : **-**

Produced by: **ELSEWEDY CABLE**
Plot No. 27, 1st District, 5th Settlement - New Cairo - Egypt

In the manufacturing plant: **PI.T00096**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZZ of the standard **EN 50575:2014 + A1:2016** under system **1+** are applied and that **the product fulfills all the prescribed requirements set out above.**

IMQ
Direttore Tecnico CPR
(Ing. V. Baggio)

This certificate was first issued on **2019-12-16** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Milano, 2019-12-16