



INSPECTION CERTIFICATE Nr 191

BV Job nr: EGY.09.02.15.40

PROJECT: type test for 1x 2500 mm ² – CU/XLPE/CW/LEAD/HDPE 130/230 kV Power Cable	Ref:---
BV Client: EL SEWEDY CABLES EGYPT	P/o nr:--- (client to BV)
Manufacturer: EL SEWEDY CABLES EGYPT	P/o nr:--- (client to Manufacturer)
Inspection requested by: EL SEWEDY CABLES EGYPT	

SUPPLY / SUBJECT OF INSPECTION	ITEM / TAG Nr	QTY
1x2500 mm ² CU/XLPE /CW/LEAD/HDPE 130/230 kV Power Cable	--	1 sample

Scope of inspection: Witness type test for 1x2500mm² CU/XLPE/CW/LEAD/HDPE 130/230 kV power cable.

- **Particulars:** None.
- **Reference documents used for inspection:** IEC 62067:2006
- **Place of inspection & date or period:** El Sewedy Cables Egypt Factory, 10th of Ramadan City, Period from November 06, 2010 to December 06, 2010.
- **Marking and stamping:** None.
- **Annexes to this certificate:** None.

The undersigned, inspector to Bureau Veritas, certifies that the hereabove mentioned supply was inspected in conformity with the applicable requirements of the purchase order and the contractual requirements governing the mission entrusted to Bureau Veritas without any remarks.

Inspected by:

Name: Akram Mortada

Mohamed Hamdy

Date of issue: 18/12/2011

Inspection centre: BV Cairo**Checked by:**

Name: Medhat Mounir Signature:...

Distribution: CLIENT MANUFACTURER