

REPORT OF PERFORMANCE

1188-15

OBJECT Single-core power cable

127/220 (245) kV – 1x800 mm² – Cu – XLPE

CLIENT Elsewedy Cables,
Algiers, Algeria

MANUFACTURERS Elsewedy Cables,
Algiers, Algeria

TESTED BY KEMA Nederland B.V.,
Arnhem, The Netherlands

DATE OF TESTS 12 March to 3 June 2015

TEST SPECIFICATION The programme was specified by the client (see page 2). The test procedures and parameters were based on IEC 62067 (2011).

SUMMARY AND CONCLUSION The object passed the tests.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This report consists of 39 pages in total.

Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.

A blue ink signature of J.P. Fonteijne, written in a cursive style.

J.P. Fonteijne
Executive Vice President
KEMA Laboratories

Arnhem, 13 July 2016

CONTENTS

page

| | | |
|--------|--|----|
| 1 | Identification of the object tested | 4 |
| 1.1 | Ratings/characteristics of the object tested | 4 |
| 1.1.1 | Characteristics of the cable | 4 |
| 1.1.2 | Characteristics of the cable | 4 |
| 1.2 | List of drawings | 8 |
| 2 | General information | 9 |
| 2.1 | The tests were witnessed by | 9 |
| 2.2 | The tests were carried out by | 9 |
| 2.3 | Subcontracting | 9 |
| 2.4 | Purpose of the tests | 9 |
| 2.5 | Measurement uncertainty | 9 |
| 3 | Electrical type tests on complete cable | 10 |
| 3.1 | Test arrangement | 10 |
| 3.1.1 | Determination of the cable conductor temperature | 10 |
| 3.1.2 | Test set-up | 11 |
| 3.1.3 | Photograph of test set-up | 12 |
| 3.2 | Test voltage values | 13 |
| 3.3 | Bending test | 14 |
| 3.4 | Partial discharge test at ambient temperature | 15 |
| 3.5 | Tan δ measurement | 16 |
| 3.6 | Heating cycle voltage test | 17 |
| 3.7 | Partial discharge test at ambient temperature | 18 |
| 3.8 | Lightning impulse voltage test | 19 |
| 3.9 | Power frequency voltage test | 22 |
| 3.10 | Examination of cable | 23 |
| 3.10.1 | Photograph of cable | 24 |
| 3.11 | Examination of cable with a longitudinally applied metal tape or foil, bonded to the oversheath | 25 |
| 3.13 | Resistivity of semi-conducting screens | 26 |
| 4 | Non-electrical type tests on cable components and on complete cable | 27 |
| 4.1 | Check of cable construction | 27 |
| 4.2 | Tests for determining the mechanical properties of insulation before and after ageing | 29 |
| 4.3 | Tests for determining the mechanical properties of oversheaths before and after ageing | 30 |

| | | |
|-------|--|----|
| 4.4 | Ageing tests on pieces of complete cable to check compatibility of materials | 31 |
| 4.5 | Pressure test at high temperature on oversheath..... | 32 |
| 4.6 | Hot set test for XLPE insulation | 33 |
| 4.7 | Measurement of carbon black content of black PE oversheaths..... | 34 |
| 4.8 | Water penetration test..... | 35 |
| 4.8.1 | Photograph of test set-up of water penetration test..... | 36 |
| 4.9 | Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath | 37 |
| 5 | Drawings | 38 |
| 6 | Measurement uncertainty | 39 |

1 IDENTIFICATION OF THE OBJECT TESTED

1.1 Ratings/characteristics of the object tested

1.1.1 Characteristics of the cable

Rated voltage, U_0/U (U_m) 127/220 (245) kV

Rated maximum conductor temperature 90 °C

Rated conductor cross-section 800 mm²

The test voltages and calculated nominal field stresses were based on U_0 test = 127 kV.

1.1.2 Characteristics of the cable

Standard IEC 62067, Clause 6

Manufacturer (as stated by the client) Elsewedy,
Algiers, Algeria

Type $U_0=127$ kV, 1x800mm², CU/XLPE/CW/HDPE CABLE

Manufacturing year 2012

Quantity submitted 81 m

Rated voltage, U_0/U (U_m) 127/220 (245) kV

Overall diameter (D) 100,1 mm

Calculated nominal electrical stress at
conductor screen at $U_0 = 127$ kV (E_i) 8,72 kV/mm

Calculated nominal electrical stress at
insulation screen at $U_0 = 127$ kV (E_o) 4,02 kV/mm

Nominal capacitance between conductor
and metal screen 0,179 µF/km

Marking on the oversheath CEI 62067 – GRTE/CEEG – EL SEWEDY CABLES ALG
- 800 CU – PR – 22 – Cuivre – 127/220 (72.5) kV – 2012
– Lot 1 - 1

Construction see drawing

Conductor

- material soft annealed copper
- material designation IEC 60228
- DC conductor resistance $\leq 0,0221 \Omega/\text{km}$
- cross-section 800 mm^2
- nominal diameter (d) 34,5 mm
- type circular compacted
- number and nominal diameter of wires 61 wires and $\varnothing 4,31 \text{ mm}$
- maximum conductor temperature in normal operation 90 °C
- presence and nature of measures to reduce skin effect no
- presence and nature of measures to achieve yes longitudinal watertightness
- swelling material swelling tape
- number of layers of swelling tapes 3
- nominal thickness and width of tape 3 x 0,1 mm touched 50-75-100 mm
- material designation kept in KEMA Laboratories'file
- manufacturer of the material United Metal- Elsewedy

Conductor screen

- material semi-conducting
- nominal thickness 1,4 mm
- material designation kept in KEMA Laboratories'file
- manufacturer of the material kept in KEMA Laboratories'file

Insulation

- material XLPE
- nominal thickness 22,0 mm
- nominal inner diameter of the insulation 37,6 mm
- nominal outer diameter of the insulation 81,6 mm
- material designation kept in KEMA Laboratories'file
- manufacturer of the material kept in KEMA Laboratories'file

Insulation (core) screen

- material extruded semi-conductive
- nominal thickness 1,4 mm
- material designation kept in KEMA Laboratories'file
- manufacturer of the material kept in KEMA Laboratories'file

Longitudinally watertightness

- presence and nature of measures to achieve yes, swelling tape longitudinal watertightness along insulation screen
- number of swelling tapes 1
- nominal thickness and width 70 x 1,0 mm (overlap: 30%)
- material designation semi-conductive swelling tape
- manufacturer of the material kept in KEMA Laboratories'file

Metal screen

- material copper tape, 1 layer, and copper wires
- number of wires 77
- nominal diameter of wires 1,43 mm
- number of tapes 1
- nominal thickness and width of tape 20 x 0,1 mm open helix
- cross-sectional area 123,67 mm²
- DC resistance 0,144 Ω /km
- manufacturer of the material United metal Elsewedy
- semi-conductive water blocking white

Metal foil or tape, longitudinally applied, bonded to the oversheath

- material yes
- nominal thickness aluminum laminated tape 0,2 mm

Oversheath

- material PE type ST₇
- nominal thickness 4,0 mm
- nominal overall diameter of the cable (D) 100,1 mm
- material designation kept in KEMA Laboratories'file
- manufacturer of the material kept in KEMA Laboratories'file
- colour black
- graphite coating applied yes

Fire retardant

- Fire retardant no
- (acc. IEC 60332-1)

Manufacturing details insulation system

- | | |
|---|--------------------------------|
| – location of manufacturing | Algiers, Algeria |
| – type of extrusion line | CCV |
| – type of extrusion | triple common extrusion |
| – factory identification of extrusion line | CCV |
| – manufacturer of the extrusion line | Maillefer - Finland |
| – identification of production batch | 1 |
| – curing means | dry |
| – cooling means | dry |
| – manufacturing length (where cable sample for testing has been taken from) | 400 m |
| – length markings on cable sample sent to KEMA Laboratories | begin: 10.199 m, end: 10.280 m |

1.2 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawing. KEMA Laboratories has verified that this drawing adequately represent the object tested. The manufacturer is responsible for the correctness of this drawing and the technical data presented.

The following drawing has been included in this report:

Drawing No./document No.

DB8-TX01-K70-17-00

Revision

0

2 GENERAL INFORMATION

2.1 The tests were witnessed by

| Name | Company |
|--|--------------------------------------|
| Mr Rriadh Fellouh (20 to 22 May 2015) | Elsewedy Cables, Algiers, Algeria |
| Mr Banoun Lamine Mr Boucif Smail (20 to 22 May 2015) | CEEG Sonelgaz, Algiers, Algeria |

2.2 The tests were carried out by

| Name | Company |
|---|---|
| Mr A. Sengers Mr S. Smeenk Mr L. Scheltinga | KEMA Nederland B.V., Arnhem, The Netherlands |

2.3 Subcontracting

The following tests were subcontracted to DNV-GL/NET (former KEMA/NET):

- measurement of resistivity of semi-conducting screens in accordance with Subclause 12.4.9
- non- electrical type tests in accordance with Subclause 12.5, with the exception of the water penetration test of Subclause 12.5.14.

2.4 Purpose of the tests

Purpose of the tests was to verify whether the material complies with the specified requirements.

2.5 Measurement uncertainty

A table with measurement uncertainties is enclosed in this report. Unless otherwise stated, the measurement uncertainties of the results presented in this report are as indicated in that table.

3 ELECTRICAL TYPE TESTS ON COMPLETE CABLE

3.1 Test arrangement

3.1.1 Determination of the cable conductor temperature

Standard

Standard IEC 62067, Annex A, Subclause A.3.1


For the tests with the cable system at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the test loop in order to create the same environmental conditions as for the test loop.

The heating currents in the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. Annex A was used as a guide and Subclause A.3.1, method 1 was applied.

The tests at elevated temperature are carried out after the conductor temperature has been within the stated limit for at least 2 hours.

3.1.2 Test set-up

In order to perform the test, the following test loop was prepared by staff of KEMA Laboratories:



- 1 piece of power cable type 1x800mm², CU/XLPE/CW/HDPE CABLE, 16 meters long.

3.1.3 Photograph of test set-up



3.2 Test voltage values

Standard and date

Standard IEC 62067, Subclause 12.4.1

Test date 12 March 2015

Characteristic test data

Length of cable sample 0,5 m

| Nominal insulation thickness (mm) | Measured average insulation thickness (mm) | Deviation of measured average insulation thickness from nominal insulation thickness (%) |
|-----------------------------------|--|--|
| 22,0 | 21,7 | -1,4 |

Requirement

If the average thickness of the insulation does not exceed the nominal value by more than 5%, the test voltages shall be the values specified in Table 4 for the rated voltage of the cable.

If the average thickness of the insulation exceeds the nominal value by more than 5% but by no more than 15%, the test voltage shall be adjusted to give an electrical stress at the conductor screen equal to that applying when the average thickness of the insulation is equal to the nominal value, and the test voltages are the normal values specified for the rated voltage of the cable.

The cable length used for the electrical type tests shall not have an average thickness exceeding the nominal value by more than 15%.

Result

The measured average insulation thickness did not exceed the nominal value by more than 5%. The voltage tests can be performed with the values specified before.

3.3 Bending test

Standard and date

Standard IEC 62067, Subclause 12.4.3

Test date 12 March 2015

Environmental conditions

Ambient temperature 4 °C

Characteristic test data

Temperature of test object 15 °C

Maximum bending diameter $25(d + D) + 5\%$

Length of cable bended 50 m

Length marking of cable bended 10.199 – 10.249m

| Nominal outer diameter of cable D (mm) | Nominal diameter of cable conductor d (mm) | Maximum required bending diameter D _r (mm) | Diameter of test cylinder D _t (mm) |
|---|---|--|--|
| 34,5 | 100,1 | 3365 | 3250 |

Result

The test was carried out successfully.

3.4 Partial discharge test at ambient temperature

Standard and date

Standard IEC 62067, Subclause 12.4.4

Test date 20 March 2015

Environmental conditions

Ambient temperature 20 °C

Characteristic test data

Temperature of test object 20 °C

Circuit direct

Calibration 5 pC

Noise level at 1,5 U_0 2 pC

Declared sensitivity 4 pC

Required sensitivity ≤ 5 pC

Centre frequency 134 kHz

Bandwidth (Δf) 100 kHz

Test frequency 50 Hz

Coupling capacitor 833 pF

| Assembly | Voltage applied, 50 Hz | | Duration (s) | Partial discharge level (pC) |
|--------------|------------------------|-------|-----------------|---------------------------------|
| | ... x U_0 | (kV) | | |
| Cable system | 1,75 | 222,3 | 10 | - |
| | 1,5 | 190 | - | Not detectable |

Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,5 U_0 .

Result

The object passed the test.

3.5 Tan δ measurement

Standard and date

Standard IEC 62067, Subclause 12.4.5

Test date 23 March 2015

Environmental conditions

Ambient temperature 21 °C

Characteristic test data

Temperature of test object 97 °C

Length of test object 16,25 m

Standard capacitor 57,38 pF

| Assembly | Voltage applied, 50 Hz (kV) | Capacitance of main loop ¹⁾ (μF/km) | Tan δ |
|------------------------------------|-----------------------------|--|----------------------|
| Cable system | 127 | 0,161 | $1,5 \times 10^{-4}$ |
| ¹⁾ for information only | | | |

RequirementThe measured value shall not be higher than 10×10^{-4} at U_0 .**Result**

The object passed the test.

3.6 Heating cycle voltage test

Standard and date

Standard IEC 62067, Subclause 12.4.6

Test dates 24 March to 20 May 2015

Environmental conditions

Ambient temperature 20-22 °C

Characteristic test data

Heating method conductor current

Stabilized temperature 97 °C

Diameter of U-bend 3365 mm

| No. of heating cycles | Required steady conductor temperature (°C) | Heating current during steady condition (A) | Heating cycle | | | Voltage | |
|-----------------------|--|---|--------------------|---|--------------------|--------------------|-----|
| | | | Heating | | Cooling | Total duration (h) | |
| | | | Total duration (h) | Duration of conductor at steady temperature (h) | Total duration (h) | | |
| 20 | 95-100 | approx. 1678 | ≥ 8 | ≥ 2 | ≥ 16 | 24 | 254 |

Requirement

No breakdown shall occur.

Result

The object passed the test.

3.7 Partial discharge test at ambient temperature

Standard and date

Standard IEC 62067, Subclause 12.4.4

Test date 20 May 2015

Environmental conditions

Ambient temperature 21 °C

Characteristic test data

Temperature of test object 21 °C

Circuit direct

Calibration 5 pC

Noise level at 1,5 U_0 2,5 pC

Declared sensitivity 5 pC

Required sensitivity ≤ 5 pC

Centre frequency 134 kHz

Bandwidth (Δf) 100 kHz

Test frequency 50 Hz

Coupling capacitor 833 pF

| Assembly | Voltage applied, 50 Hz | | Duration (s) | Partial discharge level (pC) |
|--------------|------------------------|-------|-----------------|---------------------------------|
| | ... x U_0 | (kV) | | |
| Cable system | 1,75 | 222,3 | 10 | - |
| | 1,5 | 190 | - | Not detectable |

Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,5 U_0 .

Result

The object passed the test.

3.8 Lightning impulse voltage test

Standard and date

Standard IEC 62067, Subclause 12.4.7.2

Test date 21 May 2015

Environmental conditions

Ambient temperature 22 °C

Characteristic test data

Temperature of test object 97 °C

Specified test voltage 1050 kV

| Testing arrangement | | Polarity | Voltage applied | No. of impulses | See figure on next pages |
|---------------------|---------------|----------|---------------------|-----------------|--------------------------|
| Voltage applied to | Earthed | | (% of test voltage) | | |
| Conductor | Metal screens | Positive | 50 | 1 | 1 (waveshape) |
| | | | 65 | 1 | 2 |
| | | | 80 | 1 | 2 |
| | | | 100 | 10 | 3 and 4 |
| Conductor | Metal screens | Negative | 50 | 1 | 5 (waveshape) |
| | | | 65 | 1 | 6 |
| | | | 80 | 1 | 6 |
| | | | 100 | 10 | 7 and 8 |

Requirement

The assembly shall withstand without failure or flashover 10 positive and 10 negative voltage impulses.

Result

The object passed the test.

Lightning impulse test with positive voltage




Fig. 1: Waveshape +50% of test voltage




Fig. 2: +65% and +80% of test voltage




Fig. 3: +100% of test voltage




Fig. 4: +100% of test voltage

Lightning impulse test with negative voltage




Fig. 5: Waveshape -50% of test voltage




Fig. 6: -65% and -80% of test voltage




Fig. 7: -100% of test voltage




Fig. 8: -100% of test voltage

3.9 Power frequency voltage test

Standard and date

Standard IEC 62067, Subclause 12.4.7.2

Test date 22 May 2015

Environmental conditions

Ambient temperature 21 °C

Characteristic test data

Temperature of test object 21 °C

| Testing arrangement | | Voltage applied, 50 Hz | | Duration |
|---------------------|--------------------|------------------------|------|----------|
| Voltage applied to | Earth connected to | ... x U_0 | (kV) | (min) |
| Conductors | Metal screens | 2 | 254 | 15 |

Requirement

No breakdown of the insulation shall occur.

Result

The object passed the test.

3.10 Examination of cable

Standard and date

Standard IEC 62067, Subclause 12.4.8.1

Test date 26 May 2015

Requirement

Examination of the cable shall reveal no signs of deterioration (e.g. electrical degradation, leakage, corrosion or harmful shrinkage) which could affect the system in service operation.

Result

No signs of electrical degradation, leakage, corrosion or harmful shrinkage which could affect the system in service operation were detected.

3.10.1 Photograph of cable



After examination of the cable

3.11 Examination of cable with a longitudinally applied metal tape or foil, bonded to the oversheath

Standard and date

Standard IEC 62067, Subclause 12.4.8.2

Test date 27 May 2015

Characteristic test data

Length of cable sample 1 m

| Item | Unit | Requirement | Measured/determined |
|--|------|--------------------------|--------------------------|
| Visual examination | - | No cracks or separations | No cracks or separations |
| Adhesion strength of metal foil | N/mm | $\geq 0,5$ | 0,5 |
| Peel strength of overlapped metal foil | N/mm | $\geq 0,5$ | 1,0 |

Result

The object passed the test.

3.13 Resistivity of semi-conducting screens

Standard and date

Standard IEC 62067, Subclause 12.4.9

Test date 1 April 2015

Characteristic test data

Temperature during ageing 100 °C

Duration 7 x 24 h

Resistivity measured at 90 ± 2 °C

| Item | Unit | Requirement | Measured/determined |
|-------------------|------------------|-------------|---------------------|
| Conductor screen | | | |
| – without ageing | Ωm | ≤ 1000 | 34 |
| – after ageing | Ωm | ≤ 1000 | 19 |
| Insulation screen | | | |
| – without ageing | Ωm | ≤ 500 | 1 |
| – after ageing | Ωm | ≤ 500 | 1 |

Result

The object passed the test.

4 NON-ELECTRICAL TYPE TESTS ON CABLE COMPONENTS AND ON COMPLETE CABLE

4.1 Check of cable construction

Standard and date

Standard IEC 62067, Subclause 12.5.1

Test date 17 March 2015

| Item | Unit | Requirement | Specified | Measured/determined |
|---|------|-------------|---------------|----------------------|
| Conductor | | | | |
| Diameter of conductor | mm | ≤ 37,6 | 34,5 | 34,5 |
| Number of segments | - | - | 1 | 1 |
| Number of wires | - | ≥ 53 | 61 | 61 |
| Diameter of wires | mm | - | 4,31 | 4,19 |
| Resistance at 20 °C | Ω/km | ≤ 0,0221 | ≤ 0,0221 | 0,0219 |
| Semi-conducting water blocking layer (black) | | | | present |
| Number of layers | - | - | | Cannot be determined |
| Thickness of layers | mm | - | | |
| Width of layers | mm | - | | |
| Semi-conducting conductor screen | | | | |
| Nominal thickness | mm | - | 1,4 | - |
| Average thickness | mm | - | 1,4 | 1,6 |
| Minimum thickness | mm | - | 1,0 | 1,2 |
| Outer diameter of conductor screen | mm | - | approx.. 37,5 | 37,8 |
| Insulation | | | | |
| Nominal thickness | mm | - | 22,0 | - |
| Average thickness | mm | - | - | 21,7 |
| Minimum thickness [t _{min}] | mm | - | - | 21,1 |
| Maximum thickness [t _{max}] | mm | - | - | 22,1 |
| (t _{max} – t _{min}) / t _{max} | - | ≤ 0,10 | - | 0,04 |
| Semi-conducting insulation screen | | | | |
| Nominal thickness | mm | - | 1,4 | - |
| Average thickness | mm | - | - | 1,4 |
| Minimum thickness | mm | - | > 1,2 | 1,2 |
| Outer diameter of insulation screen | mm | - | - | 85,0 |

| Item | Unit | Requirement | Specified | Measured/determined |
|---|---|--------------------------|-----------|---------------------|
| Semi-conducting water blocking layer (black) | | | | |
| Number of layers | - | - | 1 | 1 |
| Thickness of layers | mm | - | 1,0 | 0,97 |
| Width of layers | mm | - | 70 | 68 |
| overlap | % | | 30 | 26 |
| Copper screen | | | | |
| Number of Cu wires | - | - | 77 | 77 |
| Diameter of Cu wires | mm | - | 1,43 | 1,42 |
| Dimensions of Cu tape | mm | - | 0,1 x 20 | 0,07 x 19,83 |
| Cross-section of Cu screen | mm ² | - | 123,67 | |
| Diameter over Cu screen | mm | - | - | Approx. 89,5 |
| Semi-conducting water blocking layer (white) | | | | |
| Number of layers | - | - | - | 1 |
| Thickness of layers | mm | - | 0,3 | Approx. 0,3 |
| Width of layers | mm | - | - | 57,3 |
| overlap | % | | | 30 |
| Metal foil bonded to the oversheath | | | | |
| Material | | Aluminium laminated tape | | present |
| Nominal thickness | mm | - | 0,2 | |
| Oversheath | | | | |
| Nominal thickness | mm | - | 4,0 | - |
| Average thickness | mm | - | - | 4,30 |
| Minimum thickness | mm | ≥ 3,30 | - | 3,86 |
| Outer diameter | mm | - | 100,1 | 98,7 |
| Graphite coating | - | - | yes | yes |
| Colour of the oversheath | - | - | black | black |
| Marking on oversheath | CEI 62067 – GRTE/CEEG – EL SEWEDY CABLES ALG – 800 CU – PR – 22 - CUIVER – 127/220 (72.5) kV – 2012 – Lot 2 - 1 | | | |

Result

The object passed the test.

4.2 Tests for determining the mechanical properties of insulation before and after ageing

Standard and date

Standard IEC 62067, Subclause 12.5.2

Test date 7 April 2015

Characteristic test data

Temperature during ageing $135 \pm 3 \text{ }^{\circ}\text{C}$

Ageing duration 7 x 24 h (19 March to 26 March 2015)

| Item | Unit | Requirement | Measured/determined |
|---------------------------------|-------------------|-----------------------|---------------------|
| Without ageing | | | |
| Tensile strength | N/mm ² | $\geq 12,5$ | 28,2 |
| Elongation at break | % | ≥ 200 | 559 |
| After ageing in air oven | | | |
| Tensile strength | | | |
| – value after ageing | N/mm ² | - | 27,3 |
| – variation | % | $\pm 25 \text{ max.}$ | -3 |
| Elongation at break | | | |
| – value after ageing | % | - | 568 |
| – variation | % | $\pm 25 \text{ max.}$ | 2 |

Result

The object passed the test.

4.3 Tests for determining the mechanical properties of oversheaths before and after ageing

Standard and date

Standard IEC 62067, Subclause 12.5.3

Test date 3 April 2015

Characteristic test data

Temperature during ageing $110 \pm 2 \text{ }^{\circ}\text{C}$

Ageing duration 10 x 24 h (23 March to 2 April 2015)

| Item | Unit | Requirement | Measured/determined |
|---------------------------------|-------------------|-------------|---------------------|
| Without ageing | | | |
| Tensile strength | N/mm ² | $\geq 12,5$ | 38,1 |
| Elongation at break | % | ≥ 300 | 864 |
| After ageing in air oven | | | |
| Tensile strength | | | |
| – value after ageing | N/mm ² | - | 28,9 |
| – variation | % | - | -24 |
| Elongation at break | | | |
| – value after ageing | % | ≥ 300 | 774 |
| – variation | % | - | -10 |

Result

The object passed the test.

4.4 Ageing tests on pieces of complete cable to check compatibility of materials

Standard and date

Standard IEC 62067, Subclause 12.5.4

Test date 3 April 2015

Characteristic test data

Temperature during ageing $100 \pm 2 \text{ }^{\circ}\text{C}$

Ageing duration 7 x 24 h (17 March to 24 March 2015)

Insulation

| Item | Unit | Requirement | Measured/determined |
|---------------------------------|-------------------|-----------------------|---------------------|
| Without ageing | | | |
| Tensile strength | N/mm ² | $\geq 12,5$ | 28,2 |
| Elongation at break | % | ≥ 200 | 559 |
| After ageing in air oven | | | |
| Tensile strength | | | |
| value after ageing | N/mm ² | - | 33,2 |
| variation | % | $\pm 25 \text{ max.}$ | 18 |
| Elongation at break | | | |
| value after ageing | % | - | 602 |
| variation | % | $\pm 25 \text{ max.}$ | 8 |

Oversheath

| Item | Unit | Requirement | Measured/determined |
|---------------------------------|-------------------|-------------|---------------------|
| Without ageing | | | |
| Tensile strength | N/mm ² | $\geq 12,5$ | 38,1 |
| Elongation at break | % | ≥ 300 | 864 |
| After ageing in air oven | | | |
| Tensile strength | | | |
| value after ageing | N/mm ² | - | 35,3 |
| variation | % | - | -7 |
| Elongation at break | | | |
| value after ageing | % | ≥ 300 | 785 |
| variation | % | - | -9 |

Result

The object passed the test.

4.5 Pressure test at high temperature on oversheath

Standard and date

Standard IEC 62067, Subclause 12.5.6

Test date 25 March 2015

Characteristic test data

Temperature $110 \pm 2 \text{ }^{\circ}\text{C}$

Heating time 6 h

| Item | Unit | Requirement | Measured/determined |
|----------------------|------|-------------|---------------------|
| Depth of indentation | % | ≤ 50 | 4 |

Result

The object passed the test.

4.6 Hot set test for XLPE insulation

Standard and date

Standard IEC 62067, Subclause 12.5.10

Test date 19 March 2015

Characteristic test data

Air temperature $200 \pm 3 \text{ }^{\circ}\text{C}$

Time under load 15 min

Mechanical stress 20 N/cm^2

| Item | Unit | Requirement | Measured/determined |
|------------------------------------|------|-------------|---------------------|
| Elongation under load | % | ≤ 175 | 63 |
| Permanent elongation after cooling | % | ≤ 15 | -6 |

Result

The object passed the test.

4.7 Measurement of carbon black content of black PE oversheaths

Standard and date

Standard IEC 62067, Subclause 12.5.12

Test date 7 April 2015

| Item | Unit | Requirement | Measured/determined |
|----------------------|------|---------------|---------------------|
| Carbon black content | % | $2,5 \pm 0,5$ | 2,2 |

Result

The object passed the test.

4.8 Water penetration test

Standard and date

Standard IEC 62067, Subclause 12.5.14

Test dates 21 May to 3 June 2015

Environmental conditions

Ambient temperature 20-22 °C

Characteristic test data

Length of cable sample 8 m

Water height 1 m above cable centre

Heating method conductor current

| No. of heating cycles | Required steady conductor temperature (°C) | Heating current during steady condition (A) | Heating cycle | | |
|-----------------------|--|---|--------------------|---|--------------------|
| | | | Heating | | Cooling |
| | | | Total duration (h) | Duration of conductor at steady temperature (h) | Total duration (h) |
| 10 | 95 - 100 | approx. 1675 | ≥ 8 | ≥ 2 | ≥ 16 |

| Item | Unit | Requirement | Measured/determined |
|--------------------------------|------|-------------|--------------------------------|
| Water penetration under sheath | cm | ≤ 400 | Side 1, 12 cm Side 2, 13 cm |
| Water penetration conductor | cm | ≤ 400 | Side 1, 27 cm Side 2, 29 cm |

Note

The manufacturer has claimed that barriers have been included, which prevents longitudinal water penetration in the region of the metallic layers and along the conductor.

Result

The object passed the test.

4.8.1 Photograph of test set-up of water penetration test



4.9 Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath

Standard and date

Standard IEC 62067, Subclause 12.5.15

Test date 8 April 2015

Characteristic test data


Length of cable sample 1 m

| Item | Unit | Requirement | Measured/determined |
|--|------|--------------------------|--------------------------|
| Visual examination | - | No cracks or separations | No cracks or separations |
| Adhesion strength of metal foil | N/mm | $\geq 0,5$ | 0,5 |
| Peel strength of overlapped metal foil | N/mm | $\geq 0,5$ | 0,8 |

Result

The object passed the test.

5 DRAWINGS



| Size : 1X 800 mm ² | | Type : CU/XLPE/CW/HDPE | |
|--------------------------------------|-------------------------------------|--|----------------|
| Voltage: 127/ 220 kV | | Standard: IEC 62067,60228 | |
| Code : DB8-TX01-K70-17-00 | | ELSEWEDY CABLES | |
| Sr. | Description | thickness mm | Diameter mm |
| 1. | Copper Conductor | | 34.5 |
| 2. | Semi conductive Tape | 0.1 | |
| 3. | Extruded Inner semi conductive | 1.4 | |
| 4. | XLPE insulation | 22 | |
| 5. | Extruded Outer semi conductive | 1.4 | |
| 6. | Semi conductive water blocking tape | 0.3 | |
| 7. | Copper wires screen | 77 x 1.43 | |
| 8. | Open Helix copper tape | 0.1 | |
| 9. | Non conductive water blocking tape | 0.3 | |
| 10. | Aluminum laminated tape | 0.05/0.2/0.05 | |
| 11. | High density poly ethylene (HDPE) | 4 | |
| 12. | Graphite Coating | | Approx.100.3 |
| Not to Scale | | Drawn by Mr. Hussieny ahmed Approved by Eng. Ayman El kholy | |

6 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

| Measurement | Measurement uncertainty |
|--|--|
| Dielectric tests and impulse current tests: | |
| – peak value | $\leq 3\%$ |
| – time parameters | $\leq 10\%$ |
| Capacitance measurement | 0,3% |
| Tan δ measurement | $\pm 0,5\% \pm 5 \times 10^{-5}$ |
| Partial discharge measurement: | |
| – < 10 pC | 2 pC |
| – 10 to 100 pC | 5 pC |
| – > 100 pC | 20% |
| Measurement of impedance AC-resistance measurement | $\leq 1\%$ |
| Measurement of losses | $\leq 1\%$ |
| Measurement of insulation resistance | $\leq 10\%$ |
| Measurement of DC resistance: | |
| – 1 to 5 $\mu\Omega$ | 1% |
| – 5 to 10 $\mu\Omega$ | 0,5% |
| – 10 to 200 $\mu\Omega$ | 0,2% |
| Radio interference test | 2 dB |
| Calibration of current transformers | $2,2 \times 10^{-4} I_i/I_u$ and 290 μrad |
| Calibration of voltage transformers | $1,6 \times 10^{-4} U_i/U_u$ and 510 μrad |
| Measurement of conductivity | 5% |
| Measurement of temperature: | |
| – -50 to -40 °C | 3 K |
| – -40 to 125 °C | 2 K |
| – 125 to 150 °C | 3 K |
| Tensile test | 1% |
| Sound level measurement | type 1 meter as per IEC 60651 and ANSI S1,4,1971 |
| Measurement of voltage ratio | 0,1% |