

# TEST REPORT

NO. 2598.2121026.0676

Elsewedy SEDCO for Electrical Industries  
 Industrial Zone (A1)  
 PC #36A  
 10<sup>th</sup> of Ramadan City  
 EGYPT

CLIENT

Elsewedy SEDCO for Electrical Industries

MANUFACTURER

Cross bonding link box

TEST OBJECT

CR3LB.4\*1.CC.WIGUG

TYPE

Test sample

SERIAL NO.

Rated DC withstand voltage	25	kV	RATED
Rated lightning impulse withstand voltage	40 (60)	kV	CHARACTERISTICS
Rated peak withstand current	63	KA	GIVEN BY THE
Rated short-time withstand current	40	KA	CLIENT
Rated duration of short-circuit	1	s	
Permissible values for internal arcing			
Symmetrical short-circuit current	16	KA	
Duration of short-circuit	0.2	s	
Degree of protection			IPX8

Client's Instructions and KHARAMAA Specifications

NORMATIVE DOCUMENT

- Dielectric tests
- Leakage current test
- Measurement of contact resistance
- Measurement of insulation resistance
- Proof of the degree of protection IPX8
- Short-time withstand current tests
- Test under conditions of arcing due to an internal fault
- Measurement of residual voltage

RANGE OF TESTS PERFORMED

07 November 2012 to 01 March 2013

DATE OF TEST

All acceptance criteria for the performed tests based on client's instructions and KHARAMAA Specifications were met.

TEST RESULT

H. GLABSCH  
 Senior engineer  
 Berlin, 29 April 2013

M. HESKE  
 Test engineer in charge

