

TEST REPORT

NO. 2589.2130438.0864

Elastimold Egypt / Elsewedy SEDCO Subsidiaries of Elsewedy Electric
 Plot 27,
 1st District, 5th Settlement
 New Cairo 11835
 EGYPT

CLIENT

Elastimold Egypt – Subsidiary of Elsewedy Electric
 PC#36 A,
 South (A'1), Industrial Region
 10th of Ramadan City

MANUFACTURER

Premolded slip-on outdoor termination for three-core power cables with TEST OBJECT
 extruded XLPE insulation

TEST OBJECT

3C MTG

TYPE

| Test samples | SERIAL NO. | | |
|---|------------|---------|------------------------------|
| Rated voltage | U_0/U | 8.7/15 | KV RATED |
| Maximum value of highest system voltage | U_m | 17.5 | KV CHARACTERISTICS |
| Rated cross-section range | | 3 x 300 | mm ² GIVEN BY THE |
| | | | CLIENT |

Clients instructions and SEC Specifications 12-SDMS-01 Rev. 01-2010 NORMATIVE
 with reference to IEEE 048-2009, IEEE 404-2006 and IEC 60507-3: 2013 DOCUMENT

| • Partial discharge test | RANGE OF TESTS PERFORMED |
|----------------------------------|--------------------------|
| • AC voltage withstand test | |
| • DC voltage withstand test | |
| • Impulse voltage withstand test | |
| • Cyclic aging test | |
| • Short time current test | |
| • Salt fog test | |

From 07 November 2013 to 10 January 2014

DATE OF TEST

All acceptance criteria for the performed tests based on clients TEST RESULT
 instructions and SEC Specifications 12-SDMS-01 Rev. 01-2010 with
 reference to IEEE 048-2009, IEEE 404-2006 and IEC 60507-3: 2013
 were met.

D. JEGUST
 Senior engineer

M. HESKE
 Test engineer in charge

Berlin, 03 March 2014

