

Certificate of Product Approval

Certificate Number: 1285a

Issue: 03

EI SEWEDY CABLES – EGYPT (EGYTECH CABLES)

3rd Industrial Zone A3
10TH of Ramadan City
EGYPT



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
FIRE GUARD 1000 PLUS
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7846:2009 Cat F2 & F120

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward
Certification Scheme Manager

12 April 2016
Date of Issue

03 December 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1285a EI SEWEDY CABLES – EGYPT (EGYTECH CABLES)

Issue: 03

| Product name | | LPCB Ref. No. |
|---|-------------------|---|
| FIRE GUARD 1000 PLUS | | 1285a/01 |
| Nominal csa of conductor (mm ²) | Core Construction | BS 7846 |
| 25 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 35 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 50 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 70 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 95 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 120 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 150 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 185 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 240 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 300 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |
| 400 | 4 ⁽¹⁾ | F2 ⁽²⁾ & F120 ⁽³⁾ |

Uo/U 600/1000V

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward
Certification Scheme Manager

12 April 2016
Date of Issue

03 December 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 1285a EI SEWEDY CABLES – EGYPT (EGYTECH CABLES)

Issue: 03

Notes:

1. Stranded conductors only.
2. In meeting the requirements to BS 7846:2009 Category F2, the FIRE GUARD 1000 PLUS cables listed met the requirements for smoke density of EN 61034-2:2005, fire resistance requirements to BS 6387:2013 Categories CWZ and achieved less than 0.5%HCI for the insulation, tapes, filler, bedding and outer covering when tested in accordance with EN 50267-2-1:1999.
3. In meeting the requirements of BS 7846:2009 Category F120, the FIRE GUARD 1000 PLUS cables listed met the requirements for 120 minutes fire resistance to BS 8491:2008.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward
Certification Scheme Manager

12 April 2016
Date of Issue

03 December 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre