

ASTA CERTIFICATE OF TYPE TESTS

Project No: G104431584 **Certificate No:** ASTA-TYPE-000549R1

Applicant: Elsewedy Transformers, 10th of Ramadan City Zone A4, Egypt.

Apparatus: Three-phase, 1000 KVA, 11± 2x2.5% / 0.415kV (U_r), 50Hz, AN, Category 1, Dyn11, Class F insulation, cast resin dry type transformer with enclosure. LI/AV: 75 kVp / 28 kV, - /3 kV.
The principal tap was nominated by the manufacturer as tap 3.

Manufactured By: Elsewedy Transformers, 10th of Ramadan City Zone A4, Egypt.

Test Report No: 01102468-1

Designation: SWD 1000/11

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 60076-11: Edition 2.0 2018-08 Clauses 14.2.1, 14.2.3 to 14.2.7, 14.3.1, 14.3.2 and 14.4.2 and the STL Guide to IEC 60076, Issue 6.0, 1st June 2019, where applicable.


The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.



010


.....
Elamporos

Certification Engineer


.....

Certification Officer

18th November 2020
.....

Date